

① ROOF TRUSS SECTION

(F) WALL TO ROOF CONN

① GARAGE LOFT SECTION

⑥ INTERIOR SHEARWALL

⑤ WALL TO ROOF CONN.

H GABLE WALL BRACING

B INTERIOR FOUNDATION

JOINT ROOF TRUSS SECTION

(K) TRUSS AT NON-BR'G WALLS

© RETAINING FOUNDATION

D SITE RETAINING WALL

STRUCTURAL NOTES

STEEL REINFORCING:

CONCRETE BLOCK MASONRY :

CONCRETE BLOCK MASONRY :

10. ALL REINFORCING STEEL SHALL CONFORM TO ASTM A-615 GRADE 40 FOR #4 AND SMALLER BARS. ALL REINFORCING SHALL BE FREE FROM DIRT, GREASE, RUST, OR OTHER FOREIGN SUBSTANCE THAT MAY PREVENT PROPER BONDING. ALL REINFORCING BAR BENDS ARE TO BE MADE CON. ALL BARS TO BE BENT ONE TIME ONLY.